



TO: Superintendent and Board of Education

FROM: Steve Dunn

DATE: December 8, 2015

SUBJECT: December Board Report

Buildings and Grounds: The Technology Education building heating issues have been repaired. The boiler dialing for the District is still on-going due to some unforeseen issues and that we have not had any colder weather. Working on a few new roof leaks which was expected as the rubber membrane cools down. It loses its ability to stretch and it can tear. There are a couple leaks at the Island School also that we are working on. Also, we installed two outdoor basketball hoops behind school last month.

Transportation and Vehicles: The 2008 mini bus received new rear tires and a total front brake job last week. Bus #2 had the parking brake replaced along with new speedometer head and sensor. The newer mini bus will be swapped with the older one on the island this week.

Safety and Crisis Management: Fire alarm system: It is working as of now, but the main computer board has a ground fault in it and I have two companies looking into the best case scenario to either repair or replace.

Planning and Projecting: Planning roof repairs and getting outside of the building ready for winter.

Staffing and Personnel: Nothing to report.